

**Federal Register / Vol. 53, No. 185 /
Friday, September 23, 1988 /
Rules and Regulations 37203**

§ 280.44 Methods of release detection for piping.

Each method of release detection for piping used to meet the requirements of §280.41 must be conducted in accordance with the following:

(a) Automatic line leak detectors. Methods which alert the operator to the presence of a leak by restricting or shutting off the flow of regulated substances through piping or triggering an audible or visual alarm may be used only if they detect leaks of 3 gallons per hour at 10 pounds per square inch line pressure within 1 hour. An annual test of the operation of the leak detector must be conducted in accordance with the manufacturer's requirements.